


NOTES:

- 1. NUMBER OF ROWS MAY VARY.
- ROW AND SAND BED LENGTH MAY VARY.
- 3. SYSTEM SAND BED AREA WILL VARY WITH NATIVE SOIL LOADING RATE.
- 4. DEPTH OF TOPSOIL IN ACCORDANCE WITH STATE RULES.
- 5. A MINIMUM OF 6' OF SYSTEM SAND BELOW, 3" OVER AND 6" BETWEEN PEI PIPES.
- 6. BED DISTANCE ABOVE ORIGINAL GRADE MAY VARY.
- 7. DBOX MAY NOT BE REQUIRED IN YOUR STATE.



Presby Environmental, Inc.

143 Airport Road Whitefield, NH 03598

www.PresbyEnvironmental.com

An Infiltrator Water Technologies Company Phone: 800-473-5298 Fax: 603-837-9864

The PEI Wastewater Treatment System

Mound System

Drawn by	Checked	DWG#	Date	Job#
PEI			3-10-20	